COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

				OR COMPRESSE	•		
1	Manufacturer:	Gardr	ner Denver				
	Model Number: L290RS-340hp-190psi				Date:		
2	X Air-cooled Water-cooled				Type:	Screw	
					# of Stages:	1	
3*	Full Load Operat	Full Load Operating Pressure b				psig	
4	Drive Motor No	minal Ratin	g	340		hp	
5	Drive Motor Nor	Prive Motor Nominal Efficiency				percent	
6	Fan Motor Nomi	an Motor Nominal Rating (if applicable)				hp	
7	Fan Motor Nomi	nal Efficie	ncy	86.7 / 90.4		percent	
8*	Input Power (kW)			Capacity (acfm) a,d	1	Specific Power (kW/100 acfm) ^d	
	300.86			1201.0		25.05	
	249.32			1002.5		24.87	
	201.05			803.3		25.03	
	155.89			603.1	Ž	25.85	
	113.68			402.1	28.27		
	74.20		c d	199.7		37.15	
9*	Total Package In	Total Package Input Power at Zero Flow c, d				kW	
10	Isentropic Efficient	ency		73.28		%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00					
		15.00	ote: Y-Axis Scale, 10 to 35	600.0 800.0 Capacity (ACFM) risual representation of the data in the control of the data in the data in the control of the data	n Section 8	200.0 1400.0	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS160-290C