## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Displacement** 

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer:	Gardn	er Denver							
	Model Number:	SAV-3	50hp-EAY-125ր	osi			Date:		01/04/21	
2	X Air-cooled Water-cooled						Type:		Screw	
	X Lubrica	ted (	Oil Free			# (	of Stages:		1	
3*	Full Load Opera	ting Pressur	e <sup>b</sup>		125		b psig			
4	Drive Motor No	Drive Motor Nominal Rating					hp			
5	Drive Motor Nominal Efficiency				95.8		percent			
6	Fan Motor Nominal Rating (if applicable)				20		hp			
7	Fan Motor Nomi		89.5		percent					
8*	Input Power	(kW)		Capa	Capacity (acfm) <sup>a,d</sup>			Specific Power (kW/100 acfm) d		
	313.6							21.87		
	291.8				1291		22.60			
	253.3				1004 25.23					
	221.2				717		30.85			
	211.7				574		36.88			
9*	Total Package Ir	Total Package Input Power at Zero Flow c, d			63.1		kW			
10	Specific Power (kW/100 ACFM)	40.00 35.00 30.00 25.00 20.00 15.00 0	200 400  Note: Graph is only a ote: Y-Axis Scale, 10 to 3 X-Axis Sca		entation of the	nts if necessary		1400	1600	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	<u>ft<sup>3</sup> / min</u>	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.2

6/20 Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: EAY99J