				MODEL DATA - FOR COMPRES	SED AIR		
	1	Manuf	acturer:	Gardner Denver			
		Model	Number:	STG2-125HP-150psi	Date:	7/21/2020	
	2	X	Air-cooled	Water-cooled	Type:	Screw	
					# of Stages:	1	
	3*	Rated C	apacity at Full L	oad Operating Pressure <sup>a, e</sup>	560.0	acfm <sup>a,e</sup>	
	4*		d Operating Pressure <sup>b</sup>		150	psig <sup>b</sup>	
	5	Maximu	m Full Flow Op	erating Pressure <sup>c</sup>	150 125	psig <sup>c</sup> hp	
	6		otor Nominal R				
	7	Drive M	otor Nominal E	tor Nominal Efficiency		percent	
	8	Fan Motor Nominal Rating (if applicable)			95.4 5	5 hp	
	9	Fan Mot	tor Nominal Effi	ciency	85.5	percent	
	10*	Total Pa	ckage Input Pov	ver at Zero Flow <sup>e</sup>	29	kW <sup>e</sup>	
	11	Total Pa		ver at Rated Capacity and Full Load	112.40	kW <sup>d</sup>	
	12*	Package Pressure	-	at Rated Capacity and Full Load Operating	20.10	kW/100 cfm <sup>e</sup>	
	13	Isentrop	ic Efficiency		82.41	Percent	
		CAGI webs : a. b.	ite for a list of part Measured at the dis ISO 1217, Annex C The operating press for this data sheet. Maximum pressure	Performance Verification Program, these items are icipants in the third party verification program: charge terminal point of the compressor package in accord ; ACFM is actual cubic feet per minute at inlet conditions ure at which the Capacity (Item 3) and Electrical Consum attainable at full flow, usually the unload pressure setting	<u>www.cagi.org</u> lance with ption (Item 11) were measure for load/no load control or th	ed	
<b>U</b>	١IJ		Total package input Tolerance is specific	attainable before capacity control begins. May require ad power at other than reported operating points will vary we ed in ISO 1217, Annex C, as shown in table below:	ith control strategy.		
Compressed	Air & Gas Institute	NOTE: The terms "power" and "energy" are synonymous for purposes of this Volume Flow Rate			s document.	Specific Energy	No Load / Zero Flow
			at specified conditions		Volume Flow Rate	Consumption	Power
Me	mber		<u>m<sup>3</sup> / min</u>	<u>ft<sup>3</sup> / min</u>	%	%	%
			Below 0.5 0.5 to 1.5	Below 17.6 17.6 to 53	+/- 7 +/- 6	+/- 8 +/- 7	

ROT 030.1

1.5 to 15

Above 15

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 5

+/- 4

53 to 529.7

Above 529.7

+/- 10%

+/- 6

+/- 5