COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
	Model Number: VST90-60hp(2S)-100psi		Date: 01/04/21				
2	Air-cooled X Water-cooled		Type: Screw				
		# O	f Stages: 2				
3*	Full Load Operating Pressure b	100	psig b				
4	Drive Motor Nominal Rating	2 x 60	hp				
5	Drive Motor Nominal Efficiency	94.0	percent				
6	Fan Motor Nominal Rating (if applicable)	NA	hp				
7	Fan Motor Nominal Efficiency	NA	percent				
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	114.04	677.0	16.85				
	94.12	575.5	16.36				
o	76.98	473.9	16.24				
	61.68	372.4	16.56				
	47.27	270.8	17.46				
	24.70 c, d	115.0	21.48				
9*	Total Package Input Power at Zero Flow	0.0	%				
10	Isentropic Efficiency	pic Efficiency 79.67					
11	35.00 30.00 25.00 25.00 15.00 10.00 200.0	300.0 400.0 500.0 Capacity (ACFM)	600.0 700.0 800.0				
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B