	MODEL DATA - FOR COMPRESS	SED AIR		
1	Manufacturer: Gardner Denver			
	Model Number: STG2-200HP-200psi	Date:	7/21/2020	
2	X Air-cooled Water-cooled	Type:	Screw	
		# of Stages:	1	
3*	Rated Capacity at Full Load Operating Pressure a, e	724.0	acfm ^{a,e}	
4*	Full Load Operating Pressure ^b	200	psig ^b	
5	Maximum Full Flow Operating Pressure ^c	200	psig ^c	
6	Drive Motor Nominal Rating	200	hp	
7	Drive Motor Nominal Efficiency	96.2	percent	
8	Fan Motor Nominal Rating (if applicable)	5	hp	
9	Fan Motor Nominal Efficiency	85.5	percent	
10*	Total Package Input Power at Zero Flow ^e	37.9	kW ^e	
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	180.10	kW^d	
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	24.90	kW/100 cfm ^e	
13	Isentropic Efficiency	76.96	Percent	
	lels that are tested in the CAGI Performance Verification Program, these items are v CAGI website for a list of participants in the third party verification program: a. Measured at the discharge terminal point of the compressor package in accord	www.cagi.org	administrator.	
	 ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consump for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for the statement of the s	ption (Item 11) were measure		

tute 🔪	NOTE: The terms "power" and "energy" are synonymous for purposes of this document.							
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Fl Power			
	$\frac{m^3 / min}{m}$	$\underline{\text{ft}^3} / \underline{\min}$	%	%	%			
	Below 0.5	Below 17.6	+/- 7	+/- 8				
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%			
	Above 15	Above 529.7	+/- 4	+/- 5				

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.