COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MOI	DEL DATA - F	OR COMPRESSED	AIR	
1	Manufacturer:	Gardı	ner Denver			
	Model Number: VST55-37hp(2S)-100psi X Air-cooled Water-cooled			si	Date:	
2					Type:	Screw
				#	of Stages:	2
3*	Full Load Operating Pressure b			100	. b psig	
4	Drive Motor No	Drive Motor Nominal Rating			hp	
5	Drive Motor Nominal Efficiency			94.0	percent	
6	Fan Motor Nominal Rating (if applicable)			5	hp	
7	Fan Motor Non	ninal Efficie	ncy	85.5	percent Specific Power	
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	(kW/100 acfm) ^d	
	72.10		436.0	16.54		
	60.86			370.6	16	5.42
0	51.44			305.2	16.85	
	42.79			239.8	17	7.84
	33.81			174.4	19	0.39
	24.80		c, d	117.0	21.20	
9*	Total Package Input Power at Zero Flow			0.0		kW
10	Isentropic Efficiency			76.66		%
11		35.00				
		30.00				
	er M)	25.00				
	Specific Power (kW/100 ACFM)	23.00				
	Spec (kW/	20.00				
		15.00				
		10.00	1 1	1 1	1	
		0.0	50.0 100.0 150.0		350.0 400.0	450.0 500.0
		Ν	lote: Y-Axis Scale, 10 to 35	Capacity (ACFM) visual representation of the data in S 5, + 5kW/100acfm increments if necess e, 0 to 25% over maximum capacity	Section 8 ary above 35	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B