## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
	Model Number: L29RS-40hp-190psi		Date:	02/11/21			
2	X Air-cooled Water-cooled		Type:	Screw			
		#	of Stages:	1			
3*	Full Load Operating Pressure b	125	psig b				
4	Drive Motor Nominal Rating	40	hp				
5	Drive Motor Nominal Efficiency	91.7	percent				
6	Fan Motor Nominal Rating (if applicable)	1.15	hp				
7	Fan Motor Nominal Efficiency	82.5	percent				
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	37.83	175.8	21.52				
0*	31.63	148.2	21.34				
8*	25.99	120.6	21.55				
	20.85	93.0	22.42				
	16.16	65.4	24.71				
	11.89	37.8	31.46				
9*	Total Package Input Power at Zero Flow c, d	4.5	kW				
10	Isentropic Efficiency	67.93		%			
11	35.00 30.00 25.00 15.00 20.00 40.0 60.0 80.0 100.0 120.0 140.0 160.0 180.0 200.0  Capacity (ACFM)  Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}^3} / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: I RS23-29