## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MODEL DA	ATA - FOR	COMPRESSE	ED AIR		
1	Manufacturer:	Gardner Denv	er				
	Model Number: VST75-50hp(2S)-100psi  X Air-cooled Water-cooled			Date:		01/04/2	
2					Type:	Screw	
					# of Stages:	2	
3*	Full Load Operating Pressure b			100		psig	
4	Drive Motor Nominal Rating			2 x 50		hp	
5	Drive Motor Nominal Efficiency			94.0		percent	
6	Fan Motor Nominal Rating (if applicable)		cable)	5		hp	
7	Fan Motor Nomi	Fan Motor Nominal Efficiency		85.5	ļ.,,	percent	
8*	Input Power (kW)		Ca	apacity (acfm) <sup>a,d</sup>		Specific Power (kW/100 acfm) <sup>d</sup>	
	91.99			564.0		16.31	
	78.21			479.4		16.32	
	64.85			394.8		16.43	
	52.46			310.2		16.91	
	40.76			225.6		18.07	
	24.80			117.0		21.20	
9*	Total Package Input Power at Zero Flow c, d			0.0		kW	
10	Isentropic Efficiency			79.22		%	
11	wer FM)	35.00					
	(a)	20.00					
		10.00	200.0	300.0	400.0 50	0.0 600.0	
				ity (ACFM)			
			Scale, 10 to 35, + 5kW/	presentation of the data /100acfm increments if ne % over maximum capacity	cessary above 35		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B