## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Gardne	r Denver						
	Model Number: L132RS		Date:	12/17/21				
2	Air-cooled X Water-cooled			Type:	Screw			
				# of Stages:	1			
3*	Full Load Operating Pressure		125	b psig				
4	Drive Motor Nominal Rating	Drive Motor Nominal Rating		hp				
5	Drive Motor Nominal Efficie	Drive Motor Nominal Efficiency		percent				
6	Fan Motor Nominal Rating (if applicable)		0.9	hp				
7	Fan Motor Nominal Efficiency		72.0	percent				
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	153.60		791.0	19.42				
0*	126.27		678.9	18.60				
8*	103.94		563.9	18.43				
	81.47		445.5	18.29				
	59.91		321.3	18.65				
	37.63		179.0	21.02				
9*	Total Package Input Power a	otal Package Input Power at Zero Flow c, d		kW				
10	Isentropic Efficiency	ntropic Efficiency		%				
11	35.00 30.00 30.00 25.00 20.00 15.00							
	10.00  10.00  100.0 200.0 300.0 400.0 500.0 600.0 700.0 800.0 900.0  Capacity (ACFM)  Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity							

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS90-1321