## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Gardner Denver						
	Model Number: VST55-37hp(2S)-100psi			Date:	01/04/21			
2	Air-coo	oled X Water-cooled		Type:	Screw			
			#	of Stages:	2			
3*	Full Load Opera	ating Pressure b	100	•	psig b			
4	Drive Motor No	ominal Rating	2 x 37	hp				
5	Drive Motor No	ominal Efficiency	94.0	percent				
6	Fan Motor Nom	ninal Rating (if applicable)	NA	hp				
7	Fan Motor Non	ninal Efficiency	NA	percent Specific Power				
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	(kW/100 acfm) <sup>d</sup>				
	71.41		436.0	16.38				
	60.45		370.6	16.31				
O	51.26		305.2	16.79				
	42.67		239.8	17.80				
	33.68		174.4	19.31				
	24.80	c d	0.0	21.20				
9*		Total Package Input Power at Zero Flow c, u			kW			
10	Isentropic Effic	iency	77.06		%			
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00						
		Note: Y-Axis Scale, 10 to 3	Capacity (ACFM)  a visual representation of the data in Security (35, + 5kW/100acfm increments if necessarile, 0 to 25% over maximum capacity	ction 8	50.0 500.0			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B