COMPRESSOR DATA SHEET



In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Displacement

1	Manufacturer: Gardner E	Denver				
	Model Number: SAVG2-10	00hp-125psi		Date:	01/04/21	
2	Air-cooled X Water-cooled			Type:	Screw	
	X Lubricated Oil	Free		# of Stages:	1 . b	
3*	Full Load Operating Pressure		125		psig	
4	Drive Motor Nominal Rating		100	hp		
5	Drive Motor Nominal Efficiency		95.4		percent	
6	Fan Motor Nominal Rating (if ap	plicable)	NA		hp	
7	Fan Motor Nominal Efficiency		NA		percent	
	Input Power (kW)		Capacity (acfm)	1.0	Specific Power (kW/100 acfm) ^d	
	90.5		467		9.38	
8*	77.0		382	20	0.16	
	62.9		282	22	22.30	
	57.4		238	24	4.12	
	56.5		189	29	9.89	
9*	Total Package Input Power at Ze	ro Flow ^{c, d}	19.8		kW	
10	Isentropic Efficiency at Full Flow Capacity and Full Load Operatin	77.5		%		
11	35.00 30.00 30.00 25.00 25.00 15.00					
		100 150	200 250 30 Capacity (ACFM)	00 350 400	450 500	

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
 - manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

ROT 032.1

	Volume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
$\underline{m^3 / \min}$	$\underline{ft^3} / \underline{min}$	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	., 10,0	
Above 15	Above 529.7	+/- 4	+/- 5		

6/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: SAV75-100G2B